

Higgins Lake Utilities Authority (HLUA)
PO Box 437
Higgins Lake, MI 48627

Policy Number: 2023-05,
replaces 2021-05

Grinder Pump Dwelling Electrical Connection Policy

This policy, dated March 23, 2023, is to create a policy regarding the electrical connection between the dwelling and grinder pump station in the Camp Curnalia Cottage Owners Association (CCCOA) collection system owned by the HLUA.

Only simplex grinder pump stations can be connected to the dwelling's electrical service, at this time.

Cabin owner must supply a 240v 30amp disconnect in an area designated by the HLUA, and must provide proof of approved electrical inspection by local electrical inspector. Cabin owner must provide electrical service to grinder pump station at all time.

Alarm panel will be placed on dwelling next to electrical disconnect provided by cabin owner.

Cabin owner will be invoiced for all costs incurred by the HLUA to connect the grinder pump station to the dwelling's electrical service. An estimate of costs to be incurred by the HLUA and paid by cabin owner, will be provided as they are available.

CCCOA is responsible for all costs incurred by the HLUA and all corrective action required by the HLUA, due to violation of the above policy or failure of the cabin owner to pay costs incurred by the HLUA.

Motion by: Cook, Seconded by: Riley, Roll Call Vote: Cook-Yes, Keipert-Yes, Riley-Yes, King-Absent, Adopted: March 23, 2023